

Interested Bidders must provide CIF quotations via-Ocean Freight to Chuuk Port Micronesia, College of Micronesia-FSM P.O Box 879 Weno, Chuuk FM 96942 Phone: (691)330-2689

Generator Specifications for Chuuk Campus:

1-unit, Denyo Diesel Generator, Model DCA-220SPK3 ATS Spec; 3 phase; 4 wires 220V/60hz. Output: 220KVA:

Spare Components parts/Supplies to match the unit

- 1- Each Automatic transfer Switch – 600A; Model: ATS-600RC-S; outdoor type

Spare parts:

5-ea. Oil Filter

3 ea. Fuel Filter

3 ea. Air filter

3 ea. Fan/Alternator Belt

Interested Bidder must provide quotations via-Ocean freight to Pohnpei Port Micronesia, College of Micronesia-FSM, National Campus, Pohnpei FM 96941 phone (691) 320-2480

Generator Specifications for National Campus:

1 unit, Denyo Diesel Generator, Model: DCA-220SPK3 with ATS spec; 3 phase; 4 wires 220V/60hz. Output: 220KVA

Spare components parts/Supplies to match the unit

- 1- Each Automatic Transfer Switch; Model: ATS 800A outdoor type

Spare parts:

5 ea. Oil Filters

3 ea. Fuel Filters

3 ea. Air Filters

3 ea. Fan/Alternator Belt

Generator Specifications for National Campus:

- 1- Unit Denyo Diesel Generator; Model: DCA-60ESI2; output: 60KVA
3phase, 4 wires 60hz./220V with Auto start and stop Modification

Spare components parts/Supplies to match the unit:

- 1 – ea. Automatic Transfer Switch Model: ATS-200RC-0 200A; outdoor wall mount type

Spare parts:

5 ea. Oil Filters

3 ea. Fuel Filters

3 ea. Air Filters

3 ea. Fan/Alternator Belt